

SECTION 07190
(07 19 16)
WATER REPELLENTS

(Water repellent specification to reduce water absorption into medium and normal weight decorative block, concrete brick, cast concrete, cementitious stucco, and clay brick and mortar)

The intent of this guide specification is to assist in creating a project specification and is not intended to be used as a "stand alone" specification. Please read the specification carefully and modify it as needed to fit the needs of your particular project.

OKON S-20 is a water-base, low VOC, high performance ready-to-use, penetrating silane/siloxane water-repellent designed for dense concrete and masonry surfaces. As it penetrates into the surface it reacts with minerals within the substrate and creates a hydrophobic barrier against water intrusion.

PART - 1 GENERAL

1.1 SUMMARY – This section includes:

- A. Water based silane/siloxane water repellent sealer for exterior vertical above grade surfaces as scheduled.

1.2 System description –

- 1. Performance requirements: The application of water repellent shall provide finished surfaces uniform in color without altering the natural texture of the substrate, and shall resist water penetration from rainfall.

B. Related Sections include the following:

- 1. Section 03 30 00 - Cast-in-Place Concrete.
- 2. Section 03 41 00 – Precast Structural Concrete.
- 3. Section 04 21 00 – Masonry Assemblies Unit Masonry.

Note 1 – Cross reference Section 04 20 00 with this section.

Specification must include waterproofing of the backside of parapet walls with flexible membrane. This should be done by extending the roof membrane up the backside of the wall under a metal cap on the parapet wall or application of flexible waterproofing membrane per Section 09 96 53.

Raked mortar joints disqualify a project for a 5-Year Warranty.

Zinsser requires that light-weight block (as defined by ASTM C-90-96) must contain an integral water repellent to be eligible for a 5-Year Warranty.

- 4. Section 09 24 00 – Portland Cement Plastering.

5. Section 04 20 00 – Concrete Unit Masonry
6. Section 07 50 00 – Membrane roofing

Note 2 – Specifications must include waterproofing of parapet caps, preferably with metal flashing, as well as the backside of all parapet walls.

7. Section 09 96 53 – Elastomeric Membrane Coating to waterproof backside of exposed parapet wall.
8. Section 09 96 66 – Graffiti Resistant Coatings

Note 3 – Specification must require that any graffiti resistant coating to be applied must be compatible with water repellent. Systems should be included in mock-up.

1.3 SUBMITTALS

- A. Comply with Section 01 33 00 Submittal Procedures
- B. Product Data: Submit manufacturer's technical bulletins and MSDS on each product.
- C. Applicator Certificates: Signed by manufacturer certifying that the applicator complies with requirements.
- D. Third-party report confirming that recommended system has been tested in accordance with ASTM E514 on similar CMU substrate and reduced water absorption by a minimum of 90 percent in comparison to untreated specimen.
- E. Certification by water repellent manufacturer that's products supplied comply with local regulations controlling VOC emissions.

1.4 QUALITY ASSURANCE

- A. Provide water repellents with the following properties based on testing manufacturer's standard products, according to test methods indicated, applied to substrates simulating project conditions using same materials and application methods to be used for project.
- B. Field Sample:
 1. Install at Project site or pre-selected area of building an area for field sample, as directed by Architect.
 2. Provide mockup of at least 100 square feet (9.3 sm) to include surface preparation, sealant joint, and juncture details and allow for evaluation of repellent performance and finish.
 3. Conduct RILEM test before and after field sample has cured three days. Adjust application until required repellent performance is achieved.
 4. Apply material in strict accordance with manufacturer's written application instructions.

5. Obtain Architect's written approval of field sample before start of material application, including approval of aesthetics, color, texture, and appearance.
6. Manufacturer's representative will review surface preparation, application, and workmanship.
7. Field sample will be standard for judging workmanship on remainder of Project.
8. Field sample must be maintained during construction for workmanship comparison.
9. Field sample must not be altered, moved, or destroyed until Work is completed and approved by Architect.

1.5 DELIVERY, STORAGE AND HANDLING

- A. Comply with manufacturer's ordering instructions and lead-time requirements to avoid construction delays.
- B. Deliver materials in manufacturer's original, unopened, undamaged containers with identification labels intact.
- C. Store in unopened containers in a cool, dry area. Keep material from freezing in the container; do not store below 35 degree F (2 degree C) or above 100 degrees F (43 degrees C).

1.6 PROJECT CONDITIONS

- A. Weather and Substrate Conditions: Do not proceed with application of water repellent under any of the following conditions, except with written instructions from the manufacturer:
 1. Ambient air and surface temperature is less than 50 degrees F.
 2. Concrete surfaces and mortar have cured less than 28 days.
 3. Rain or temperatures below 50 degrees F are predicted within 24 hours.
 4. Application is earlier than 24 hours after surface has been wet.
 5. Substrate is frozen or surface temperature is less than 50 degrees F.
 6. Windy conditions exist that may cause water repellent to be blown onto surface not intended to be coated.

1.7 WARRANTY

- A. General Warranty: The special warranty specified in the article shall not deprive the owner of other rights the owner may have under other provisions of the contract documents and shall be in addition to, and run concurrent with, other warranties made by the contractor under requirements of the contract documents.
- B. Special Warranty: Submit a written warranty, executed by the applicator and water repellent manufacturer, covering materials, agreeing to repair or replace materials that fail to provide water repellency within the specified warranty period. Warranty does not include deterioration or failure of coating due to unusual weather phenomena, failure of prepared and treated

substrate, formation of new joints and cracks in excess of 1.5 mm (1/16 inch) wide, fire, vandalism or abuse by maintenance equipment.

- C. Warranty Period: Five (5) years from date of Substantial Completion.
- D. Contractor Verification - Applicator must comply with manufacturer's warranty requirements providing written verification of total size of surface area covered and total gallons of product applied. This document will be accompanied with copies of invoices for product applied to project, including credits for any returned merchandise.
- E. Final Inspection - Manufacturer will issue the Special Warranty after completing final inspection of the Project confirming that the performance of the sealer is equal to the test wall and after receiving the completed Contractor Verification documents.

PART - 2 PRODUCTS

2.1 MANUFACTURERS

- A. Subject to compliance with requirements, products that may be incorporated into the work include, but are not limited to, the following:
 - 1. OKON S-20 Silane/Siloxane Water Repellent Sealer
Zinsser Co. Inc.
173 Belmont Dr.
Somerset, NJ 08875
732-469-8100 or Facsimile 732-652-2491
Internet Web Sites: www.okoninc.com or www.zinsser.com
- B. Substitutions: Comply with Section 01 33 00 Submittals and 01 60 00 Products

2.2 MATERIALS

- A. Water-based silane/siloxane with the following minimum performance properties:
 - 1. VOC compliant in SCAQMD - < 100 g/L
 - 2. Dept of penetration $\geq 3/8$ "

PART - 3 EXECUTION

3.1 PREPARATION

- A. Clean substrate of substances that might interfere with penetration or performance of water repellents. Remove all dust, dirt, paint, bitumens, efflorescence, oil, pollution deposits, and curing, forming, and parting compounds, other contaminants prior to application. Use abrasive brush blast or high pressure water as necessary to achieve the required surface condition.

- B. Allow power washed surfaces to dry three days prior to coating. Surface should be dry to touch and show no visible signs of moisture prior to application of water repellent.
- C. Protect adjoining work, including sealant bond surfaces, from spillage or over spray of water repellent. Cover adjoining and nearby surfaces of aluminum and glass if there is the possibility of water repellent being deposited on surfaces.
- D. Coordination with Sealants: Do not apply water repellent until sealants for joints adjacent to surfaces receiving water repellent treatment have been installed and cured.
- E. Water repellent work may precede sealant application only if sealant adhesion and compatibility have been tested and verified using substrate, water repellent, and sealant materials identical to those used in the work.
- F. Revisions of planned application, if any, as requested by Architect, will be by Change Order if application method constitutes a departure from requirements of Contract Documents at the time of contracting.

3.2 APPLICATION

3.3 Apply a heavy saturation spray coating of water repellent on surfaces indicated for treatment using pressure spray equipment. Comply with manufacturers written instructions for using airless spraying procedure, unless otherwise directed.

3.4 Follow application method and rate established by Test Area. Apply a second saturation spray coating, if required, repeating first application. Comply with manufacturers written instructions for limitations on drying time between coats. Consult manufacturer's technical representative if written instructions are not applicable to project conditions.

3.5 FIELD QUALITY CONTROL

- A. Manufacturers Field Service: Provide service of a factory authorized technical service representative to inspect and approve the substrate before application and to instruct the applicator on the product and application method to be used.

3.6 CLEANING

3.7 Protective Covering: Remove protective coverings from adjacent surfaces and other protective areas.

3.8 Immediately clean water repellent from adjoining surfaces and surfaces soiled or damaged by water repellent application as work progresses. Repair damage caused by water repellent application. Comply with manufacturers written cleaning instructions.

1. END OF SECTION 07190